



GARY TAYLOR
Mobile: 604-690-9009

P.O. Box 38562
North Vancouver, B.C.
V7M 3N1

Date: OCTOBER 18 / 2012

STRIVING TO KEEP OUR ENVIRONMENT FRIENDLY

REGARDING:

ELECTROMAGNETIC DETECTION FOR UNDERGROUND OIL TANK AT: { 1310-24th STREET
{ WEST VANCOUVER, B.C.
{ C.W.V. PRESBYTERIAN CHURCH
{

TANK DETAILS:	{	OBSERVATIONS:	{
	{		{
	{		{
	{		{
	{		{

SUMMARY:

WITH FISHER T-W 6 M-SCOPE IN HAND, AN ELECTROMAGNETIC DETECTION FOR AN
ABANDONED UNDERGROUND FUEL OIL STORAGE TANK WAS CONDUCTED ON THE ABOVE-
REFERENCED PROPERTY AND NO TANK WAS LOCATED.

IN CONCLUSION, NO EVIDENCE COLLECTED INDICATED THE PRESENCE OF AN
ABANDONED UNDERGROUND FUEL OIL STORAGE TANK OF STEEL CONSTRUCTION
ANYWHERE ON THIS PROPERTY IN ALL AREAS CHECKED EXTERIOR TO FOOTPRINT
OF HOUSE

ELECTROMAGNETIC DETECTION ACCURATE TO A DEPTH OF FIVE FEET WHEN UNDISTURBED BY SURROUNDING INTERFERENCE

APPROVAL TO COMMENCE: OCTOBER 8th / 2012

COST: \$200.00 + HST (\$24.00)

WORK COMPLETED: OCTOBER 12th / 2012

TOTAL: \$224.00

PAID IN FULL: _____

**TAYLOR OIL TANK SERVICES ENSURES THAT ALL WORK CONFORMS
TO CURRENT B.C. FIRE CODE REGULATIONS**

Quotation valid for 30 days